


Fakultet kemijskog inženjerstva i tehnologije
Zavod za termodinamiku, strojarstvo i energetiku



ENERGETIKA

Studij: Kemijsko inženjerstvo (V semestar)

prof. dr. sc. Igor Sutlović

Termoenergetska postrojenja


U termoenergetskim postrojenjima može se proizvoditi:

- samo električna energija,
- električna i toplinska energija-kogeneracije,
- samo toplinska energija (energana).


Termoenergetska postrojenja mogu postojati kao:

- zasebni objekti ili
- biti u sastavu industrijskog postrojenja
- Bez obzira da li proizvode samo električnu ili toplinsku energiju ili oboje mogu raditi zasebno (otočni pogon) ili mogu biti priključena na električnu ili toplinsku mrežu.


Princip rada termoelektrane



Kako izgleda jedno termoenergetsko postrojenje?




Teoretske osnove rada
termoelektrane –
desnokretni proces
(Rankinov) s prikazom u
T-s dijagramu



FP1 = Feed pump 1
FP2 = Feed pump 2
HPT = High pressure turbine
LPT = Low pressure turbine


“Duša” elektrane je turbina, u ovom slučaju parna, u pravilu višestupanjska

U turbini para visokog tlaka ekspandira a rad se dobiva zbog promjene tlaka i kinetičke energije (Eulerova j. za turbostrojeve)



„Hladni“ kraj

Ako je elektrana kondenzacijska ili s reguliranim oduzimanjem ako proizvodi samo struju onda para nakon ekspanzije završava u kondenzatoru




TERMOELEKTRANE u RH

TERMOELEKTRANE

RASPOLOŽIVA SNAGA NA PRAGU (Mw)

GORIVO

| | | |
|--------------|--------------|--------------------------------|
| TE Sisak | 396 | loživo ulje/ prirodni plin |
| TE-TO Zagreb | 337/ 480 MWt | prirodni plin/ loživo ulje |
| TE Rijeka | 303 | loživo ulje |
| TE Plomin 1 | 98 | ugljen |
| EL-TO Zagreb | 90/ 184 MWt | prirodni plin/ loživo ulje |
| KTE Jertovac | 83 | prirodni plin/ ekstralako ulje |
| PTE Osijek | 48/ 34 MWt | prirodni plin/ ekstralako ulje |
| TE-TO Osijek | 42 | loživo ulje/ prirodni plin |
| TE Plomin 2 | 192 | ugljen |





TE-TO Zagreb



TE Plomin1



TE Rijeka



EL-TO Zagreb



TE-TO Osijek

- U vlasništvu HEP-a je sedam termoelektrana, s tim da su **TE Sisak**, **TE Rijeka**, **TE Plomin 1** i **KTE Jertovec** kondenzacijske za proizvodnju električne energije, a **TE-TO Zagreb**, **EL-TO Zagreb** i **TE-TO Osijek** su termoelektrane toplane u kojima se u spojenom procesu proizvodi električna i toplinska energija. Kao pogonsko gorivo koriste loživo ulje, prirodni plin i ugljen.
- HEP je vlasnik 50 postotnog dijela drugog bloka TE Plomin 2, a temeljem vlasništva polovice NE Krško, hrvatskom elektroenergetskom sustavu raspoloživo je na pragu 338 MW.









| TE | TE-TO Zagreb | EL-TO Zagreb | TE Sisak | TE Rijeka |
|----------------------|---|--|--------------------------------|-------------------------------|
| POLOŽAJ | Zagreb, Žitnjak | Zagreb, Trešnjavka | Sisak, Čret | JI od Rijeke |
| TIP ELEKTRANE | kogeneracijska | kogeneracijska | kondenzacijska | regulaciona kondenzacijska |
| VRSTE GORIVA | prir. plin ili lako ulje za loženje/teško loživo ulje, plin | prir. plin, teško loživo ulje/plin | teško lož ulje, plin | teško loživo ulje |
| UKUPNA SNAGA | 328MWe/740MWt | 86,8MWe/342,34 MWt+180t/h | 420 MW (2x210 MW) | 320 MW |
| PROIZVOD | el. i topl. energija | el. i topl. energija | el. en., tehnološka para | električna energija |


| TE | TE Plomin | KTE Jertovec | TE-TO Osijek |
|----------------------|---------------------|--|--|
| POLOŽAJ | Luka Plomin | Konjščina, Jertovec | Osijek |
| TIP ELEKTRANE | kondenzacijska | interventna (vršna) | kogeneracijska |
| VRSTE GORIVA | ugljen | prirodni plin, ekstra lako ulje za loženje | <ul style="list-style-type: none">•g1: prirodni plin / l.ulje•g2: teško lož ulje / plin |
| UKUPNA SNAGA | 330 MW | 88 MW | 89 MW _e / 139 MW _t +50 t/h |
| PROIZVOD | električna energija | električna energija i usluge sustava | električne i toplinske energije |

EMISIJE U ZRAK IZ TE HEP-a



Kogeneracijska postrojenja - CHP (Combined Heat and Power)

Pojam kogeneracijskog postrojenja podrazumijeva istovremenu proizvodnju električne i toplinske energije za razliku od potpuno odvojene proizvodnje tih transformiranih oblika energije




$$\eta_0 = \frac{(E + T)}{G} = \frac{(30 + 34)}{100} = 64\%$$

$$\eta_0 = \frac{(E + T)}{G} = \frac{(30 + 34)}{(85,7 + 40)} = 51\%$$


"Topping cycle" kogeneracijska shema

Karakteristična je po tome što proizvodi el. energiju korištenjem izvora više temperature, a iz otpadne topline proizvodi paru ili vrelu vodu




Primarni pokretač – stroj koji proizvodi mehanički rad (parna turbina, plinska turbina, motor s unutrašnjim izgaranjem)

Prikazano u T-s dijagramu




Viša temperaturna razina koristi se za proizvodnju el. energije, a preostala energija namiruje potrebe za toplinskom energijom.

“Bottom cycle” kogeneracijska shema-rjeđe se koriste




Prikazano u T-s dijagramu





Viša temperaturna razina koristi se za proizvodnju el. energije, a preostala energija namiruje potrebe za toplinskem energijom.

Protutlačna turbina-koristi se kada postoji
potrošač toplinske energije s konstantnom
potrošnjom



$$N_e = \frac{D \cdot (h_1 - h_2)}{3600}$$



$$\eta_t = \frac{N_e \cdot 3600}{Q_K}$$



$$Q_K = D \cdot (h_1 - h_3) = D_g \cdot H_d \cdot \eta_K$$

$$Q_0 = D \cdot (h_2 - h_3)$$

Turbina s reguliranim oduzimanjem



Posebni slučajevi:

$D_0=0$ – postrojenje radi u kondenzacijskom pogonu

$D=D_0$ - postrojenje radi u protutlačnom pogonu – sva para nakon ekspanzije u VTT odvodi se potrošačima toplinske energije

Ukupna snaga postrojenja - električna:

$$N_e = N_{VTT} + N_{NTT} = \frac{D \cdot (h_1 - h_2) + (D - D_0) \cdot (h_2 - h_3)}{3600} \quad [\text{kW}_e]$$
$$D, D_0 \quad [\text{kg / h}]$$


Toplina odvedena u kondenzatoru:

$$Q_C = (D - D_0) \cdot (h_3 - h_4) = D_{H_2O} \cdot c_{pH_2O} \cdot \Delta T_{H_2O}$$
$$D_{H_2O} \quad [\text{kg/h}]$$

$$Q_K = D \cdot (h_1 - h_4) = D_g \cdot H_d \cdot \eta_K$$

Termodinamički stupanj djelovanja:

$$\eta_t = \frac{N_e \cdot 3600}{Q_K}$$



Ekonomičnost postrojenja – toplinski faktor iskorištenja:


$$f = \frac{N_e \cdot 3600 + Q_0}{Q_K} = \frac{N_e \cdot 3600 + Q_0}{D_G \cdot H_d \cdot \eta_K}$$

Toplina odvedena potrošaču:

$$Q_0 = D_0 \cdot (h_2 - h_4)$$

Figure 2: Equivalent Separate Heat and Power Efficiency

Assumes 40 percent efficient electric and 80 percent efficient thermal generation



Objašnjenje uz prethodni dijagram

- Stupanj iskorištenja kogeneracijskog postrojenja ovisi o omjeru proizvedene električne i toplinske energije.
- U prethodnom dijagramu na osi x označen je taj omjer (Power to Heat Ratio odn. prevedeno na hrvatski el. energija (E) naspram toplinska energija (T)). Pojasnimo to malo:

Ukupna proizvedena energija je zbroj električne i toplinske energije i označena je slovom U.

$$U = E + T$$

Uvrštavanjem ovog izraza u omjer E/T dobiva se:

$$\frac{E}{T} = \frac{E}{U - E} = \frac{E}{100 - E}$$

Proizvedena električna energija na temelju poznatog omjera E/T je:

$$E = \frac{\frac{E}{T} \cdot U}{1 + \frac{E}{T}}$$

Table III: Summary Table of Typical Cost and Performance Characteristics by CHP Technology*


| Technology | Steam Turbine ¹ | Recip. Engine | Gas Turbine | Microturbine | Fuel Cell |
|--|--|--|---|---|--|
| Power efficiency (HHV) | 15-38% | 22-40% | 22-36% | 18-27% | 30-63% |
| Overall efficiency (HHV) | 80% | 70-80% | 70-75% | 65-75% | 55-80% |
| Effective electrical efficiency | 75% | 70-80% | 50-70% | 50-70% | 55-80% |
| Typical capacity (MW _e) | 0.5-250 | 0.01-5 | 0.5-250 | 0.03-0.25 | 0.005-2 |
| Typical power to heat ratio | 0.1-0.3 | 0.5-1 | 0.5-2 | 0.4-0.7 | 1-2 |
| Part-load | ok | ok | poor | ok | good |
| CHP Installed costs (\$/kW _e) | 430-1,100 | 1,100-2,200 | 970-1,300 (5-40 MW) | 2,400-3,000 | 5,000-6,500 |
| O&M costs (\$/kWh _e) | <0.005 | 0.009-0.022 | 0.004-0.011 | 0.012-0.025 | 0.032-0.038 |
| Availability | near 100% | 92-97% | 90-98% | 90-98% | >95% |
| Hours to overhauls | >50,000 | 25,000-50,000 | 25,000-50,000 | 20,000-40,000 | 32,000-64,000 |
| Start-up time | 1 hr - 1 day | 10 sec | 10 min - 1 hr | 60 sec | 3 hrs - 2 days |
| Fuel pressure (psig) | n/a | 1-45 | 100-500 (compressor) | 50-80 (compressor) | 0.5-45 |
| Fuels | all | natural gas, biogas, propane, landfill gas | natural gas, biogas, propane, oil | natural gas, biogas, propane, oil | hydrogen, natural gas, propane, methanol |
| Noise | high | high | moderate | moderate | low |
| Uses for thermal output | LP-HP steam | hot water, LP steam | heat, hot water, LP-HP steam | heat, hot water, LP steam | hot water, LP-HP steam |
| Power Density (kW/m ²) | >100 | 35-50 | 20-500 | 5-70 | 5-20 |
| NO _x (lb/MMBtu) (not including SCR) | Gas 0.1-2 Wood 0.2-5 Coal 0.3-1.2 | 0.013 rich burn 3- way cat. 0.17 lean burn | 0.036-0.05 | 0.015-0.036 | 0.0025-.0040 |
| Ib/MWh _{TotalOutput} (not including SCR) | Gas 0.4-0.8 Wood 0.9-1.4 Coal 1.2-5.0. | 0.06 rich burn 3- way cat. 0.8 lean burn | 0.17-0.25 | 0.08-0.20 | 0.011-0.016 |


* Data are illustrative values for typically available systems; All costs are in 2007\$


¹For steam turbine, not entire boiler package

$$1\text{psi}=6894\text{Pa}$$


Kogeneracijsko postrojenje s 2 plinsko turbinska bloka i 3 generatora pare za vršno opterećenje










Kogeneracijski sustav s motorom s unutrašnjim izgaranjem (Otto/Diesel)




**CHP – proizvodnja električne energije i toplinske
energije iskorištenjem otpadnih toplina rashladne vode
motora i dimnih plinova-mtu-onsite energy**






Energetika, prof. dr. sc Igor Sutlović


Pogled na elektrogenerator



Energetika, prof. dr. sc Igor Sutlović



Mikrokogeneracija
ecoPOWER (Vaillant)



Mikrokogeneracija ecoPOWER-unutrašnjost (Vaillant)

- 1 upravljačka ploča
- 2 izmjenjivač dimnih plinova s katalizatorom
- 3 blok plinskog motora
- 4 generator
- 5 prigušivač zvuka
- 6 izmjenjivač topline
- 7 električni priključci
- 8 dovod plina
- 9 zrako-dimovod
- 10 polazni/povratni vod grijanja

Tehnički podaci

| Tip uređaja: ecoPOWER | Jedinica | |
|------------------------------|-------------------|--------------------------|
| Električna snaga | kW | modulirano 1,3 ~ 4,7 |
| Snaga grijanja | kW | modulirano 4,0 ~ 12,5 kW |
| Priključne vrijednosti: | | |
| Zemni plin, 2E (G 20) | m ³ /h | 0,6 - 1,9 |
| Ukapljeni plin, P | kg/h | 0,76 - 1,55 |
| Stupanj iskoristivosti | % | >90 |
| Radni volumen pl. motora | cm ³ | 272 |
| Broj okretaja (modulirajući) | okr/min | 1200 - 3600 |
| Maks. temp. polaznog voda | °C | 75 |
| Minim. temp. povratnog voda | °C | 60 |
| Maks. temp. dimnih plinova | °C | 120 |
| Minimalni tlak plina | mbar | 15 |
| Maks. tlak plina | mbar | 50 |
| Maks. radni tlak | bar | 3 |
| Visina | mm | 1080 |
| Širina | mm | 740 |
| Dubina | mm | 1370 |
| Težina | kg | 395 |
| Priključna snaga | A | 10 |
| Mrežni priključak | - | 3 x 400 V / 50 Hz |
| Nazivna snaga | W | 5 - 180 |
| Klasa zaštite | - | IP 200 |